



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: Chase Price

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Kenneth Parker / Jeff Winkie**  
655 Hoopers Creek  
Fletcher, NC 28732

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES201117-0079**

Date Collected: 11/16/2020

Time Collected: 08:30

By: Eric Weber

Date Received: 11/17/2020

Time Received: 09:00

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Well head

Sample Type:

GPS No.

Treatment:

Well Permit No. 17120118335

Comment:

## Colilert Profile

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/17/2020
E. coli	Absent			11/17/2020

Report Date: 11/18/2020

Reported By: **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.