

North Carolina State Laboratory of Public Health

Environmental Sciences

Inorganic Chemistry

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report to: Environmental Health

DUPLIN CO ENVIRONMENTAL HEALTH

PO BOX 948

KENANSVILLE, NC 28349

Name of System:

Tater Tots Learning Center

561 S. Sycamore St. Rose Hill, NC 28458

EIN: 566000296EH Delivery: NC Courier

Profile: Lead - Water Investigation Collection Date: 01/25/2021 Receiving Date: 01/26/2021

StarLiMS ID	Field Number	Туре	Sampling Point	Collection Time	Collected By	Lead (mg/L)
ES210126-0154-001	RFD W06978	R-FD	Kitchen Cleeaning Sink	09:30	RP	0.005
ES210126-0154-002	R30 W06978	R-30	Kitchen Cleaning Sink	09:30	RP	<0.003

Comment: Post Remediation Follow Up Sample

Report Date: 02/02/2021 Reported By:

Marc Komlos

make

EPA Safe Drinking Water Action Level for Lead is 0.015 mg/L.

Type Description

C-FD - Confirmation First Draw
R-FD - Remediation First Draw
C-30 - Confirmation 30 Seconds Flush
R-30 - Remediation 30 Seconds Flush