



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Weston Johnson

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
 610 EAST CENTER AVENUE
 Mooresville, NC 28115

Mt. Mourne Church of God

EIN: 566000037AA

Delivery: NC Courier

Iredell County

StarLiMS ID: ES210316-0023	Date Collected: 03/15/2021	Time Collected: 12:15	By: Weston Johnson
	Date Received: 03/16/2021	Time Received: 07:40	By: Ann Grant
Water System ID: 20-49-038	System Type: NC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Men's restroom	Location Type:	Location Code: 001	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/16/2021
E. coli	Absent			03/16/2021

Report Date: 03/17/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.