



# North Carolina State Laboratory of Public Health

## Environmental Sciences

### Microbiology

#### Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

#### FINAL REPORT

Report to: JONATHAN STEPP

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

David Coston  
617 Apple Valley Road  
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES210511-0050**

Date Collected: 05/10/2021

Time Collected: 08:50

By: Johnathan Stepp

Date Received: 05/11/2021

Time Received: 07:52

By: DeMonta Newborn

Sample Source: Well water

Sampling Point: kitchen sink

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

#### Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/11/2021
E. coli	Absent			05/11/2021

Report Date: 05/12/2021

Reported By: **KPLEMMONS**

#### Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.