



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Allen Baker

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Virginia Creek Campground No 7

EIN: 562033372Q

Delivery: NC Courier

Pender County

StarLiMS ID: **ES210629-0043**

Date Collected: 06/28/2021

Time Collected: 14:27 By: Allen Baker

Date Received: 06/29/2021

Time Received: 07:52 By: Denise Richardson

Water System ID: 70-71-031

System Type: NTNC

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: VC#7-G66

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: *Outward Facing Faucet

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			06/29/2021
E. coli	Absent			06/29/2021

Report Date: 06/30/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.