



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: Luke Whaley

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Amos Dawson**  
160 Little Mine Mtn. Dr.  
Saluda, NC 28773

EIN: 566000307EH

Delivery: UPS

Henderson County

StarLiMS ID: <b>ES210721-0093</b>	Date Collected: 07/20/2021	Time Collected: 08:24	By: Luke Whaley
	Date Received: 07/21/2021	Time Received: 10:28	By: Denise Richardson
Sample Source: Well water	Sampling Point: Well spigot		
Sample Type: Raw	GPS No.		
Treatment:	Well Permit No.		

Comment:

## Colilert Profile

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/21/2021
E. coli	Absent			07/21/2021

Report Date: 07/22/2021

Reported By: **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.