



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: JAMIE MIDGETTE

Name of System:

WASHINGTON REGIONAL OFFICE PWSS
943 WASHINGTON SQUARE MALL
Washington, NC 27889

Craven County Water System
4500 Adams Creek
Havelock, NC

EIN: 562033116F

Delivery: NC Courier

Craven County

StarLiMS ID: **ES210727-0042**

Date Collected: 07/26/2021

Time Collected: 11:45 By: Jamie Midgette

Date Received: 07/27/2021

Time Received: 08:08 By: DeMonta Newborn

Water System ID: 04-25-055

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Bathroom sink

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine: 0.50 mg/L mg/L

Total Chlorine:

Comments: Disinfectant Used: Chlorine.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/27/2021
E. coli	Absent			07/27/2021

Report Date: 07/29/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.