The state of the s	North Carolina State Laboratory of Public Health Environmental Sciences Microbiology			h	4312 District Drive MSC 1918 Raleigh, NC 27699-1918 http://slph.ncpublichealth.com Phone: 919-733-7308		
A CONTRACTOR OF CONTRACTOR	Certific	sis			Fax: 919-715-8611		
Report to: Allen Baker		Name of System:					
WILMINGTON REGIONAL OFFICE PWSS 127 CARDINAL DRIVE EXTENSION Wilmington, NC			Virginia Creek Campground ^{No 7} NC				
EIN: 562033372Q	Delivery: NC	Courier				Pender Count	
StarLiMS ID: ES210729-0032	Date Collected: Date Received:	07/28/2021 07/29/2021	Time Collected: Time Received:	09:55 07:41	By: By:	Allen Baker Angela Heybroek	
Water System ID: 70-71-031 Facility ID:	System Type:	NTNC	Water Source: Sample Type:		Ground Water Special/Non-Compliance		
Sample Location: Lot G66 Disinfectant Used:	Location Type: Free Chlorine:		Location Code: Total Chlorine:				
Comments:							
PWS - Colilert Profile				N	lethod: SM 9223B		
Analyte	Test Result	Unit	Conclusion		Date Tested		
Total Coliform E. coli	Absent Absent			07/29/2021 07/29/2021			

Report Date:

man

08/04/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.