



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: **Sasha Bowery**

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Grayson Laughter
309 Tullahoma Farms Lane

EIN: **566000307EH**

Delivery: **NC Courier**

Henderson County

StarLiMS ID: ES210729-0043	Date Collected: 07/28/2021	Time Collected: 09:30	By: Erin Lindsey
	Date Received: 07/29/2021	Time Received: 07:43	By: Angela Heybroek
Sample Source: Well water	Sampling Point: kitchen tap		
Sample Type:	GPS No.		
Treatment:	Well Permit No. 21090113420		

Comment:

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/29/2021
E. coli	Absent			07/29/2021

Report Date: 08/04/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.