



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Allen Baker

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Virginia Creek Campground No 7
 Lot G 74

EIN: 562033372Q

Delivery: NC Courier

Pender County

StarLiMS ID: **ES210803-0026**

Date Collected: 08/02/2021

Time Collected: 10:20 By: Allen Baker

Date Received: 08/03/2021

Time Received: 08:29 By: Angela Heybroek

Water System ID: 70-71-031

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location:

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Outward facing

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/03/2021
E. coli	Absent			08/03/2021

Report Date: 08/04/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.