



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Chase Price

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Mark Cassonin
16 Dawn Ln
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: UPS

Henderson County

StarLiMS ID: **ES210825-0069**

Date Collected: 08/24/2021

Time Collected: 08:15

By: Chase Price, Erin Lin

Date Received: 08/25/2021

Time Received: 10:32

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Well Head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. 20100119693

Comment:

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/25/2021
E. coli	Absent			08/25/2021

Report Date: 08/26/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.