



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Luke Whaley

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

John Thornton
363 Pisgah Forest Trl
Arden, NC 28704

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES210930-0104** Date Collected: 09/29/2021 Time Collected: 08:00 By: Luke Whaley
Date Received: 09/30/2021 Time Received: 08:33 By: Angela Heybroek

Sample Source: New Well Sampling Point: Well

Sample Type: GPS No.

Treatment: Well Permit No. 21100106500

Comment:

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			09/30/2021
E. coli	Absent			09/30/2021

Report Date: 10/01/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.