



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: Janet Mills**

**Name of System:**

**MOORESVILLE REGIONAL OFFICE PWSS**  
**610 EAST CENTER AVENUE**  
**Mooreville, NC 28115**

**Christ UMC**

**EIN: 566000037AA**

**Delivery: NC Courier**

**Rowan County**

StarLiMS ID: **ES211019-0032**

Date Collected: 10/18/2021

Time Collected: 12:45 By: Jaet Mills

Date Received: 10/19/2021

Time Received: 07:43 By: Angela Heybroek

Water System ID: 01-80-767

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Routine

Sample Location: Sand Step A

Location Type:

Location Code: 009

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/19/2021
E. coli	Absent			10/19/2021

**Report Date:** 10/20/2021

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.