



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: Janet Mills**

**Name of System:**

**MOORESVILLE REGIONAL OFFICE PWSS**  
**610 EAST CENTER AVENUE**  
**Mooreville, NC 28115**

**Christ UMC**

**EIN: 566000037AA**

**Delivery: NC Courier**

**Rowan County**

StarLiMS ID: <b>ES211019-0033</b>	Date Collected: 10/18/2021	Time Collected: 12:48	By: Janet Mills
	Date Received: 10/19/2021	Time Received: 07:43	By: Angela Heybroek
Water System ID: 01-80-767	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Routine	
Sample Location: Sanctuary Outside	Location Type:	Location Code: 008	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/19/2021
E. coli	Absent			10/19/2021

**Report Date:** 10/20/2021

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.