



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Janet Mills

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooreville, NC 28115

Christ UMC
3401 Mooreville Rd
Salisbury, NC 28147

EIN: 566000037AA

Delivery: NC Courier

Rowan County

StarLiMS ID: **ES211026-0002**

Date Collected: 10/25/2021

Time Collected: 13:00 By: Janet Mills

Date Received: 10/26/2021

Time Received: 07:41 By: Denise Richardson

Water System ID: 01-80-767

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Mens Room Sink

Location Type:

Location Code: 102

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/26/2021
E. coli	Absent			10/26/2021

Report Date: 10/27/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.