



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: JOEY WHITE

Name of System:

WASHINGTON REGIONAL OFFICE PWSS
943 WASHINGTON SQUARE MALL
Washington, NC 27889

Craven Co. Water
216 Barrington Way
New Bern, NC

EIN: 562033116F

Delivery: NC Courier

Craven County

StarLiMS ID: **ES211209-0040**

Date Collected: 12/08/2021

Time Collected: 10:20 By: Joey White

Date Received: 12/09/2021

Time Received: 07:51 By: Krystal Plemmons

Water System ID: 04-25-055

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location:

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine: 0.70 mg/L mg/L

Total Chlorine:

Comments: Disinfectant Used: Sodium Hypochlorite

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/09/2021
E. coli	Absent			12/09/2021

Report Date: 12/10/2021

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.