



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Erin Hughes

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Antoine Ignizio
40 Lofty Pine Ln
Mills River, NC 28759

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES220112-0095

Date Collected: 01/11/2022

Time Collected: 08:30

By: Erin Hughes, Mandi F

Date Received: 01/12/2022

Time Received: 09:06

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Kitchen sink tap

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. 21090117203

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/12/2022
E. coli	Absent			01/12/2022

Report Date: 01/13/2022

Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.