



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: TRENTON HILL

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Catherine Rausch
132 McKinley Dr
Leicester, NC 28748

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES220201-0073**

Date Collected: 01/31/2022

Time Collected: 08:45

By:

Date Received: 02/01/2022

Time Received: 08:08

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Sample head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. 21100106003

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			02/01/2022
E. coli	Absent			02/01/2022

Report Date: 02/02/2022

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.