



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: **TRENTON HILL**

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Joshua Gossett**

133 Walnut Valley Lane  
Hendersonville, NC 28739

**EIN: 566000307EH**

**Delivery: NC Courier**

**Henderson County**

StarLiMS ID: **ES220222-0008**

Date Collected: 02/21/2022

Time Collected: 08:30

By: Jesse Nardone

Date Received: 02/22/2022

Time Received: 07:30

By: Denise Richardson

Sample Source: Well water

Sampling Point: Sample head

Sample Type:

GPS No.

Treatment:

Well Permit No. 21100101210

Comment:

## Colisure Profile

**Method: SM 9223B**

<b>Analyte</b>	<b>Test Result</b>	<b>Unit</b>	<b>Conclusion</b>	<b>Date Tested</b>
Total Coliform	Absent			02/22/2022
E. coli	Absent			02/22/2022

**Report Date:** 02/23/2022

**Reported By:** **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.