



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: **Erin Hughes**

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Michael Meyer**  
5104 Greenville Hwy  
Hendersonville, NC 28792

**EIN: 566000307EH**

**Delivery: NC Courier**

**Henderson County**

StarLiMS ID: <b>ES220324-0071</b>	Date Collected: 03/23/2022	Time Collected: 08:40	By: Erin Hughes
	Date Received: 03/24/2022	Time Received: 08:05	By: Angela Heybroek
Sample Source: New Well	Sampling Point: Well head		
Sample Type: Raw	GPS No.		
Treatment:	Well Permit No. 21100118096		

Comment:

## Colisure Profile

**Method: SM 9223B**

<b>Analyte</b>	<b>Test Result</b>	<b>Unit</b>	<b>Conclusion</b>	<b>Date Tested</b>
Total Coliform	Present			03/24/2022
E. coli	Absent			03/24/2022

**Report Date:** 03/25/2022

**Reported By:** **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.