



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Allen Baker

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Handy House No 2

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: ES220412-0044	Date Collected: 04/11/2022	Time Collected: 11:25	By: Allen Baker
	Date Received: 04/12/2022	Time Received: 07:58	By: DeMonta Newborn
Water System ID: 04-16-499	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type:	
Sample Location: Raw Water	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			04/12/2022
E. coli	Absent			04/12/2022

Report Date: 04/13/2022

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.