



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Jordan Winter

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Austin Community Center
 8458 Austin Traphill Rd
 Austin, NC 28621

EIN: 566000372X

Delivery: NC Courier

Wilkes County

StarLiMS ID: ES220519-0032	Date Collected: 05/18/2022	Time Collected: 10:50	By: Jordan Winter
	Date Received: 05/19/2022	Time Received: 08:00	By: DeMonta Newborn
Water System ID: 01-97-592	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Routine	
Sample Location: Kitchen Sink	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/19/2022
E. coli	Absent			05/19/2022

Report Date: 05/20/2022

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.