



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Allen Baker

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**1140 Business Center Bldg #A**

**EIN:** 562033372Q

**Delivery:** NC Courier

**New Hanover County**

StarLiMS ID: **ES220526-0048**

Date Collected: 05/25/2022

Time Collected: 10:20 By: Allen Baker

Date Received: 05/26/2022

Time Received: 07:40 By: Denise Richardson

Water System ID: NC70-65-044

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Outside faucet by utz Location Type:

Location Code:

Disinfectant Used: Free Chlorine:

Total Chlorine:

Comments: Special / Non-compliance (SP)

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/26/2022
E. coli	Absent			05/26/2022

**Report Date:** 05/27/2022

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.