



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report to: MARY CASHWELL

Name of System:

DUPLIN CO ENVIRONMENTAL HEALTH
PO BOX 948
KENANSVILLE, NC 28349

Faison Day School
105 W.College St.
Faison, NC 28341

EIN: 566000296EH

Delivery: NC Courier

Profile: Lead - Water Investigation

Collection Date: 07/28/2022

Receiving Date: 07/29/2022

StarLiMS ID	Field Number	Type	Sampling Point	Collection Time	Collected By	Lead (mg/L)
ES220801-0018-001	W-01		Break Room Faucet First Draw	16:05	Mary Cashwell	0.053
ES220801-0018-002	W-02		Break Room Faucet 30 Sec.Fill	16:05	Mary Cashwell	0.003
ES220801-0018-003	W-03		Break Room Faucet 2 min.Fill	16:07	Mary Cashwell	0.003
ES220801-0018-004	W-04		Break Room Faucet 5 min.Fill	16:10	Mary Cashwell	<0.003

Comment:

Report Date: 08/16/2022

Reported By:

Marc Komlos

EPA Safe Drinking Water Action Level for Lead is 0.015 mg/L.

Type Description

C-FD - Confirmation First Draw
R-FD - Remediation First Draw

C-30 - Confirmation 30 Seconds Flush
R-30 - Remediation 30 Seconds Flush