



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tim Appelboom

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Bucky's Grocery
 2855 Chandler's Mill Rd
 Pelham, NC 27311

EIN: 566000372X

Delivery: NC Courier

Caswell County

StarLiMS ID: ES220823-0039	Date Collected: 08/22/2022	Time Collected: 10:10	By: Tim Appelboom
	Date Received: 08/23/2022	Time Received: 08:24	By: Angela Heybroek
Water System ID: 30-17-048	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Coffee sink	Location Type:	Location Code: E 01	
Disinfectant Used:	Free Chlorine: 0.00 mg/L	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/23/2022
E. coli	Absent			08/23/2022

Report Date: 08/24/2022

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.