4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
Phone: 919-733-7308
Fax: 919-715-8611

North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

FINAL REPORT

Report to: **Mandi Pearson**

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Name of System:

Bryan Lind
692 Lindsey Loop Rd
Fletcher, NC 28732

EIN: **566000307EH** **Delivery:** **UPS** **Henderson County**

StarLiMS ID:	ES220824-0115	Date Collected:	08/23/2022	Time Collected:	08:45	By:	Mandi Pearson and E
		Date Received:	08/24/2022	Time Received:	11:12	By:	Angela Heybroek
Sample Source:	New Well	Sampling Point:	Well Head				
Sample Type:	Raw	GPS No.					
Treatment:		Well Permit No.	21100122183				

Comment:

Colilert Profile **Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/24/2022
E. coli	Absent			08/24/2022

Report Date: 08/25/2022 **Reported By:** **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.