



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Mandi Pearson

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Edward Keith Owens**  
765 Higher Path Dr  
Saluda, NC 28773

**EIN:** 566000307EH

**Delivery:** NC Courier

Henderson County

StarLiMS ID: **ES220915-0048**

Date Collected: 09/14/2022

Time Collected: 08:45

By: Mandi Pearson

Date Received: 09/15/2022

Time Received: 08:39

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Well head

Sample Type:

GPS No.

Treatment:

Well Permit No. 055-2022-0256

Comment:

## Colilert Profile

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/15/2022
E. coli	Absent			09/15/2022

**Report Date:** 09/16/2022

**Reported By:** **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.