



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Allen Baker

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
 127 CARDINAL DRIVE EXTENSION
 Wilmington, NC

Cedar Creek Campground

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: ES221109-0074	Date Collected: 11/08/2022	Time Collected: 10:14	By: Allen Baker
	Date Received: 11/09/2022	Time Received: 09:07	By: Angela Heybroek
Water System ID: 70-16-018	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Faucet behind well	Location Type:	Location Code: E02	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	
Comments: Very windy			

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/09/2022
E. coli	Absent			11/09/2022

Report Date: 11/10/2022

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.