



# North Carolina State Laboratory of Public Health

## Environmental Sciences

### Microbiology

#### Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

#### FINAL REPORT

Report to: Jeffery Anders

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Bernard Daneansky  
294 Trillium Garden Tr  
Fletcher, NC 28732

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES221130-0089** Date Collected: 11/29/2022 Time Collected: 08:45 By: Ethan Calloway  
Date Received: 11/30/2022 Time Received: 09:13 By: Angela Heybroek

Sample Source: New Well Sampling Point: Well head  
Sample Type: GPS No.  
Treatment: Well Permit No. 21100107049

Comment:

#### Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/30/2022
E. coli	Absent			11/30/2022

Report Date: 12/01/2022

Reported By: **KPLEMMONS**

#### Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.