



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: **CURT CLINE**

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Joshua Gossett**  
133 Walnut Valley Ln  
Hendersonville, NC 28739

**EIN: 566000307EH**

**Delivery: NC Courier**

**Henderson County**

StarLiMS ID: **ES221201-0058** Date Collected: 11/30/2022 Time Collected: 08:42 By: Ethan Calloway  
Date Received: 12/01/2022 Time Received: 08:34 By: Angela Heybroek

Sample Source: New Well Sampling Point: Well head  
Sample Type: GPS No.  
Treatment: Well Permit No. 21100101210

Comment:

## Colisure Profile

**Method: SM 9223B**

<b>Analyte</b>	<b>Test Result</b>	<b>Unit</b>	<b>Conclusion</b>	<b>Date Tested</b>
Total Coliform	Absent			12/01/2022
E. coli	Absent			12/01/2022

**Report Date:** 12/02/2022

**Reported By:** **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.