



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Barry Smith
167 Broyles Rd
Hendersonville, NC 28791

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES230124-0108** Date Collected: 01/23/2023 Time Collected: 08:45 By: Quinton Powell
Date Received: 01/24/2023 Time Received: 09:10 By: Angela Heybroek

Sample Source: New Well Sampling Point: Well Head/Threadless Tap

Sample Type: Raw GPS No.

Treatment: Well Permit No. 22100103005

Comment:

Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 01/24/2023 |
| E. coli | Absent | | | 01/24/2023 |

Report Date: 01/25/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.