



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Jonathan Corbett

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Traphill Elementary School
9794 Traphill Road
Traphill, NC 28685

EIN: 566000372X

Delivery: NC Courier

Wilkes County

StarLiMS ID: ES230518-0039	Date Collected: 05/17/2023	Time Collected: 11:55	By: Jonathan Corbett
	Date Received: 05/18/2023	Time Received: 08:23	By: Shannon McCorkle
Water System ID: 01-97-429	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Kitchen sink	Location Type:	Location Code: TH1	
Disinfectant Used:	Free Chlorine: 1.04mg/L mg/L	Total Chlorine:	
Comments: Disinfectant used: Sodium Hypochlorite			

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/18/2023
E. coli	Absent			05/18/2023

Report Date: 05/19/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.