



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Walker Keel

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Jefferson Landing
140 E. Meadow Dr.
Jefferson, NC 28640

EIN: 566000372X

Delivery: NC Courier

Ashe County

StarLiMS ID: **ES230524-0059**

Date Collected: 05/23/2023

Time Collected: 12:15 By: Walter Keel

Date Received: 05/24/2023

Time Received: 07:59 By: Shannon McCorkle

Water System ID: 01-05-108

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: 140 E Meadow Dr

Location Type:

Location Code: CSA

Disinfectant Used:

Free Chlorine: 0.45 mg/L

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/24/2023
E. coli	Absent			05/24/2023

Report Date: 05/25/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.