



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Mike Lammi

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Armfield S/D Phase 1A
 6304 Matheson Ct
 Summerfield, NC

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: ES230614-0074	Date Collected: 06/13/2023	Time Collected: 12:35	By: Mike Lammi
	Date Received: 06/14/2023	Time Received: 08:36	By: Julie Schiavone
Water System ID: 30-41-054	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: outside spigot	Location Type:	Location Code: 010	
Disinfectant Used:	Free Chlorine: 0.55 mg/L	Total Chlorine:	
Comments: disinfectant used: sodium hypchlorite			

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/14/2023
E. coli	Absent			06/14/2023

Report Date: 06/15/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.