



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Mike Lammi

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Autumn Forest MHP

Browns Summit, NC 27214

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: **ES230616-0005**

Date Collected: 06/15/2023

Time Collected: 11:02 By: Mike Lammi

Date Received: 06/16/2023

Time Received: 07:32 By: Angela Heybroek

Water System ID: 02-41-103

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Outside spigot

Location Type:

Location Code: 151

Disinfectant Used:

Free Chlorine: 0.15 mg/L

Total Chlorine:

Comments: Disinfectant used: Sodium hypochlorite.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Not Tested			
E. coli	Not Tested			

Note: Analyte(s) 'Unsatisfactory' because invalid sample. Water bacteriological samples must be collected on Mon, Tues, or Wed with receipt no later than Thur.

Report Date: 06/16/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.