



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Mike Lammi

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
**450 WEST HANES MILL RD STE 300**  
**Winston Salem, NC 27105**

**Cedar Park MHP**

**EIN:** 566000372X

**Delivery:** NC Courier

**Guilford County**

StarLiMS ID: **ES230616-0006**

Date Collected: 06/15/2023

Time Collected: 10:21 By: Mike Lammi

Date Received: 06/16/2023

Time Received: 07:33 By: Angela Heybroek

Water System ID: 02-41-105

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Outside spigot

Location Type:

Location Code: 001

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Disinfectant used: Sodium hypochlorite.

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Not Tested			
E. coli	Not Tested			

Note: Analyte(s) 'Unsatisfactory' because invalid sample. Water bacteriological samples must be collected on Mon, Tues, or Wed with receipt no later than Thur.

**Report Date:** 06/16/2023

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.