



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: JOEY WHITE

Name of System:

WASHINGTON REGIONAL OFFICE PWSS
943 WASHINGTON SQUARE MALL
Washington, NC 27889

Bertie Beach

EIN: 562033116F

Delivery: NC Courier

Bertie County

StarLiMS ID: **ES230802-0058**

Date Collected: 08/01/2023

Time Collected: 10:00 By: Joey White

Date Received: 08/02/2023

Time Received: 08:38 By: Angela Heybroek

Water System ID: 60-08-000

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Restroom # 2

Location Type:

Location Code: 002

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/02/2023
E. coli	Absent			08/02/2023

Report Date: 08/03/2023

Reported By: **CGOFORTH**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.