



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Warren's Chapel Missionary BC
 Prospect Hill, NC 27314

EIN: 566000372X

Delivery: NC Courier

Caswell County

StarLiMS ID: ES230929-0016	Date Collected: 09/27/2023	Time Collected: 11:21	By: Doug Whitmire
	Date Received: 09/29/2023	Time Received: 08:00	By: Angela Heybroek
Water System ID: 30-17-026	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Women's RR	Location Type:	Location Code: WR1	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	

Comments: No disinfectant used.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Not Tested			
E. coli	Not Tested			

Note: Analyte(s) 'Unsatisfactory' because exceeded EPA allowable holding time. Sample over 30 hrs old when received. Please resample..

Report Date: 09/29/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.