



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Doug Whitmire

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Warren's Chapel Missionary Baptis**

**EIN:** 566000372X

**Delivery:** NC Courier

**Caswell County**

StarLiMS ID: <b>ES231003-0054</b>	Date Collected: 10/02/2023	Time Collected: 12:45	By: Doug Whitmire
	Date Received: 10/03/2023	Time Received: 08:32	By: Julie Schiavone
Water System ID: 30-17-026	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: women's restroom	Location Type:	Location Code: WRL	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	

Comments: disinfectant used: none

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			10/03/2023
E. coli	Absent			10/03/2023

**Report Date:** 10/04/2023

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.