



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Janet Mills

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
 610 EAST CENTER AVENUE
 Mooresville, NC 28115

Silver Maples Estates MHP
 2968 Darwin Trail
 Concord, NC 28027

EIN: 566000037AA

Delivery: NC Courier

Cabarrus County

StarLiMS ID: **ES231214-0051**

Date Collected: 12/13/2023

Time Collected: 13:00 By: Janet Mills

Date Received: 12/14/2023

Time Received: 07:53 By: Kaila Kurtz

Water System ID: 01-13-168

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: 2968 Darwin Trail

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine: 0.41 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/14/2023
E. coli	Absent			12/14/2023

Report Date: 12/15/2023

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.