



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Easton Rains

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Rocky Ridge Missionary Baptist Cl**  
 1694 US-158

**EIN:** 566000372X

**Delivery:** NC Courier

**Rockingham County**

StarLiMS ID: **ES240206-0050**

Date Collected: 02/05/2024

Time Collected: 09:54 By: Easton Rains

Date Received: 02/06/2024

Time Received: 08:48 By: Julie Schiavone

Water System ID: 02-79-545

System Type: NTNC

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: well head

Location Type:

Location Code: WH1

Disinfectant Used:

Free Chlorine:

Total Chlorine: 0.0 mg/L

Comments: No disinfectant used

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/06/2024
E. coli	Absent			02/06/2024

**Report Date:** 02/07/2024

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.