



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: TRENTON HILL

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

David Shaffer
325 Horseshoe Bend Rd

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES240229-0051

Date Collected: 02/28/2024

Time Collected: 08:30

By: Trenton Hill

Date Received: 02/29/2024

Time Received: 07:57

By: DeMonta Newborn

Sample Source: Well water

Sampling Point: Kitchen Sink

Sample Type:

GPS No.

Treatment:

Well Permit No. 0SS-2024-10

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/29/2024
E. coli	Absent			02/29/2024

Report Date: 03/01/2024

Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.