



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Matthew Leddy

Name of System:

ASHEVILLE REGIONAL OFFICE PWSS
 2090 US HIGHWAY 70
 Swannanoa, NC 28778

Little Switzerland Orchard & Brew
 477 Blue Ridge Gem Mine Rd
 Spruce Pine, NC 28777

EIN: 566000372CC

Delivery: NC Courier

Mitchell County

StarLiMS ID: **ES240508-0033**

Date Collected: 05/07/2024

Time Collected: 11:30 By: Joel Kohn

Date Received: 05/08/2024

Time Received: 08:25 By: Julie Schiavone

Water System ID: 10-61-022

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Full bathroom

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/08/2024
E. coli	Absent			05/08/2024

Report Date: 05/09/2024

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.