



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Anna Floyd

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
 610 EAST CENTER AVENUE
 Mooresville, NC 28115

Mt Hope Church

EIN: 566000037AA

Delivery: NC Courier

Rowan County

StarLiMS ID: **ES240515-0055**

Date Collected: 05/14/2024

Time Collected: 09:06 By: Anna Floyd

Date Received: 05/15/2024

Time Received: 08:55 By: Julie Schiavone

Water System ID: 01-80-595

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Dish sink

Location Type: 001

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/15/2024
E. coli	Absent			05/15/2024

Report Date: 05/16/2024

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.