



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Hannah Mitchell

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**Westport Plaza**

**EIN:** 562033372Q

**Delivery:** NC Courier

**Carteret County**

StarLiMS ID: **ES240524-0021**

Date Collected: 05/23/2024

Time Collected: 12:12 By: Hannah Mitchell

Date Received: 05/24/2024

Time Received: 09:26 By: Angela Heybroek

Water System ID: 04-16-528

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location:

Location Type: BR2

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Tap Location: Trash & Treasures

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Not Tested			
E. coli	Not Tested			

Note: Analyte(s) 'Unsatisfactory' because invalid sample. Water bacteria samples must be collected on Mon, Tues, or Wed with receipt no later than Thur.

**Report Date:** 05/29/2024

**Reported By:** **DNEWBORN**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.