



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Easton Rains

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Greensboro National Golf Club - P**  
 330 Niblick Rd  
 Summerfield, NC 27358

**EIN:** 566000372X

**Delivery:** NC Courier

**Rockingham County**

StarLiMS ID: **ES240604-0049**

Date Collected: 06/03/2024

Time Collected: 11:07 By: Easton Rains

Date Received: 06/04/2024

Time Received: 08:16 By: Julie Schiavone

Water System ID: 30-79-029

System Type: NTNC

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: Outside spigot

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine: 0 mg/L

Comments: No disinfectant used.

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/04/2024
E. coli	Absent			06/04/2024

**Report Date:** 06/05/2024

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.