



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Danny Wiedner

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**Veneer Village #2**  
 1038 Chatham St  
 Newport, NC 28570

**EIN:** 562033372Q

**Delivery:** NC Courier

**Carteret County**

StarLiMS ID: **ES240605-0044**

Date Collected: 06/04/2024

Time Collected: 10:44 By: Joshua Pack

Date Received: 06/05/2024

Time Received: 08:14 By: Julie Schiavone

Water System ID: 70-16-047

System Type:

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: outside spigot

Location Type:

Location Code: 109

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: System Type: NP. Disinfectant Used: None.

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/05/2024
E. coli	Absent			06/05/2024

**Report Date:** 06/06/2024

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.