



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Meredith Guglielmi

Name of System:

ASHEVILLE REGIONAL OFFICE PWSS
 2090 US HIGHWAY 70
 Swannanoa, NC 28778

Bethel Baptist Church-Old Sanctua

EIN: 566000372CC

Delivery: NC Courier

Haywood County

StarLiMS ID: ES240605-0045	Date Collected: 06/03/2024	Time Collected: 09:00	By: Meredith Guglielmi
	Date Received: 06/05/2024	Time Received: 08:14	By: Julie Schiavone
Water System ID: 01-44-408	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: ladies' restroom	Location Type:	Location Code: 003	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Not Tested			
E. coli	Not Tested			

Note: Analyte(s) 'Unsatisfactory' because exceeded EPA allowable holding time. Sample over 30 hrs old when received..

Report Date: 06/05/2024

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.