



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Easton Rains

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

State Road Food Mart
 1930 US Hwy 21
 State Road, NC 28676

EIN: 566000372X

Delivery: NC Courier

Surry County

| | | | |
|-----------------------------------|----------------------------|-------------------------------------|------------------|
| StarLiMS ID: ES240618-0036 | Date Collected: 06/17/2024 | Time Collected: 11:15 | By: Easton Rains |
| | Date Received: 06/18/2024 | Time Received: 08:24 | By: Kaila Kurtz |
| Water System ID: 02-86-574 | System Type: NTNC | Water Source: Ground Water | |
| Facility ID: D01 | | Sample Type: Special/Non-Compliance | |
| Sample Location: Kitchen Sink | Location Type: | Location Code: KS 1 | |
| Disinfectant Used: | Free Chlorine: | Total Chlorine: 0.0 mg/L | |

Comments: No disinfectant used

PWS - Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 06/18/2024 |
| E. coli | Absent | | | 06/18/2024 |

Report Date: 06/19/2024

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.