



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Hannah Mitchell

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**Westport Plaza**

**EIN:** 562033372Q

**Delivery:** NC Courier

**Carteret County**

StarLiMS ID: <b>ES240619-0042</b>	Date Collected: 06/18/2024	Time Collected: 14:40	By: Hannah Mitchell
	Date Received: 06/19/2024	Time Received: 07:58	By: Julie Schiavone
Water System ID: 04-16-528	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Bogue Battery	Location Type:	Location Code: BR3	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/19/2024
E. coli	Absent			06/19/2024

**Report Date:** 06/20/2024

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.